

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2020/SZ/ 238

Dated: 20 / 07 / 2020.

FIRE SAFETY CERTIFICATE

Certified that **The Indian School** located at Josip Broz Tito Marg, Near Moolchand Flyover, New Delhi-110049, comprised of Ground + 03 upper floors was issued Fire Safety Certificate by this department vide letter No.F6/DFS/MS/School/2018/SZ/2163 dated 20/09/2018. The premise was re-inspected by officers concerned by this department on 08/07/2020 in the presence of Mr. Brijesh Kumar Singh, Asstt. Admin Officer of the school and found that now the school building is comprised of **Basement, Ground +03 floors**, have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular No. 262-362 dated 17-01-2005 and that the school building is fit for occupancy class "**Educational**" Group-B (School) as above with effect from the date of issue of this certificate for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of conditions mentioned below.

Issued 20 / 07 / 2020 at New Delhi by


(Atul Garg)
Director
Delhi Fire Service


Copy to: -

- ✓ Principal, The Indian School, Josip Broz Tito Marg, Near Moolchand Flyover, New Delhi-49
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Basement shall be used strictly as per Building Bye Laws.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.


Rashi Narula
Manager


Tania Joshi
Principal
The Indian School